



Confirmation

Eurofins Product Testing A/S confirms that a sample of a sealant primer, architectural non porous with the name

UZIN PE 460
supplied by
UZIN UTZ AG

showed low VOC contents in a test in accordance with SCAQMD rule 1168 as specified in LEED 2009 credit c4.1/ LEED v4 for low emitting materials (adhesives and sealants).

VOC contents were below the limit value specified as 250 g/l VOC minus water per liters for sealant primers, architectural non porous.

Actual VOC content of the product was below 10 g/l VOC minus water.

The test has been performed in February 2014, see test report no. 392-2014-00018901.

Volatiles content was calculated by Eurofins.
Water content was given by the client.
Content of exempt compounds was set to zero.
Solids content was determined by Eurofins.

With this confirmation, use of the tested product may qualify for fulfilment of LEED 2009 credit EQ c4.1 / LEED v4 for low emitting materials (adhesives and sealants) regarding VOC content.

01 April 2014

Thomas Neuhaus
Head of product emission test centre

Eurofins Product Testing A/S
Smedeskovvej 38
DK 8464 Galten / Denmark

Tel +45 70 22 42 76
Fax +45 70 22 42 75

www.product-testing.eurofins.com